



GENERAL NOTES:

If damage occurs outside of patch location due to removal operations, the contractor shall be responsible for the cost of the repairs.

Refer to Standard Road Plans RH-50 and RH-51 for details of joint construction.

All patches shall be rectangular even when existing pavement joints are skewed.

- Joint spacing 3 meters minimum, 6 meters maximum, 4.5 meters optimum.
- The joint shall not be sawed nor sealed.
- New 'CD' Joint must be a minimum 1.5 meters from the patch end.
- Install dowels approximately mid-depth of existing P.C. Pavement.
- If one lane patch exceeds 15 meters, both lanes should be considered for patching.
- If longitudinal subdrain (shoulder) is not to be placed or if not present on side of roadway to be patched, then place proposed 75 millimeters slotted corrugated pipe at low end of patch.
- 150 millimeters granular subbase if required by plan. When placed, granular subbase should extend over longitudinal subdrain, if present.
- The joint shall be sawed and sealed after patching. Refer to RH-50 for joint details.
- If this joint is across from an existing crack or joint, then use 'RD' joint, otherwise use 'RT' joint. 'RT' joints shall not be sawed after patching nor be sealed. Refer to RH-50 for joint details.
- Mid-panel joint shall be either a 'CT' or a 'CD' joint. If there is no existing joint or crack in the adjacent pavement, place a 'CT' joint. If there is an existing joint or crack in the adjacent pavement, place a 'CD' joint at the same transverse location. 'CT' joints shall be sawed but not sealed.
- Full depth saw cut required prior to removal. Place 13 millimeters preformed joint material between patch and concrete in adjacent lane.
- If all lanes are patched at the same time, longitudinal joint will be sawed but not sealed. If patches are placed in stages, see note 2.

BAR SIZE TABLE			
Existing PCC Pavement Thickness	Less than 200 mm	250 mm or More	200 mm but less than 250 mm
DOWEL SIZE	20	30	35
TIE BAR SIZE	#20	#30	#35

All dimensions given in millimeters unless noted.

METRIC VERSION	Iowa Department of Transportation Highway Division	
	STANDARD ROAD PLAN	
	RR-14	
	REVISION: NEW; Replaces Detail Sheet 532-58	
	APPROVED BY DESIGN METHODS ENGINEER	
FULL DEPTH COMPOSITE PATCH WITH DOWELS		REVISION NO. NEW REVISION DATE 04-30-02